



Machine Learning for the Grid

**D. Deka, S. Backhaus & M. Chertkov +
A. Lokhov, S. Misra, M. Vuffray and K. Dvijotham**

DOE/OE & LANL (Grid Science) + GMLC (1.4.9 + 2.0)



D. Deka



S. Backhaus



M. Vuffray



A. Lokhov



S. Misra



K. Dvijotham (Caltech)



M. Chertkov

UNCLASSIFIED

- Intro: Overview of Challenges and Approaches
- Technical Intro: Direct and Inverse Stochastic Problem
–Machine Learning for Grid Operations
- Machine Learning for Distribution Grid
- Machine Learning for Transmission Grid
- Graphical Models & New Physics=Grid Informed Learning Tools

UNCLASSIFIED

Data Analytics can improve resiliency in the Dynamic Grid

Changes in the modern Grid:

- Penetration of Renewables
- Storage devices
- Loads becomes active (not controlled)

Challenges

- Strong fluctuations/uncertainty
- Needs real-time observability, control
- Millions of devices, many entities

New (available) Solutions

- Hardware:
Smart meters, PMUs, micro-PMUs
- Software/New algorithms:
Machine Learning, IoT

Vision:

Design Algorithms for smart meter data to learn and control (state of the grid)

Features:

- Build upon Physics of Power flow & the network/graph features.
- Scalable and computationally tractable
- Address desired (spatio-temporal) sparsity

UNCLASSIFIED


- Intro: Overview of Challenges and Approaches
- Technical Intro: Direct and Inverse Stochastic Problem
–Machine Learning for Grid Operations
- Machine Learning for Distribution Grid
- Machine Learning for Transmission Grid
- Graphical Models & New Physics=Grid Informed Learning Tools

UNCLASSIFIED

Grid should **operate** in spite of uncertainty & fluctuations

uncertainty:

- Graph **Layout** (switching of lines) + other +/- variables (transformers)
- **State Estimation** (consumption & production)
 - Deterministic static & dynamic models (e.g. relating $s=(p,q)$ to v)
 - Probabilistic (statistical) models =>



fluctuations:

- Renewable generators (wind & solar)
- loads (especially if active = involved in Demand Response)




$$s_j = \sum_{k \sim j} v_j \left(\frac{v_j - v_k}{z_{jk}} \right)^*$$

Power Flow Eqs.

Direct **Deterministic** Problem: Power Flow (static/minutes)

Given:

- operational grid=graph, inductances/resistances
- injections/consumptions (for example)



Compute:

- power flows over lines
- voltages
- phases

$$s_j = \sum_{k \sim j} v_j \left(\frac{v_j - v_k}{z_{jk}} \right)^*$$

Power Flow Eqs.

UNCLASSIFIED

Direct **Stochastic** Problem: Power Flow (static/minutes)

Given:

- operational grid=graph, inductances/resistances
- **Probability distribution (statistics)** of injections/consumptions (for example)
 - samples are assumed drawn (from the probability distribution), e.g. i.i.d.

Compute **statistics** of:

- power flows over lines
- voltages
- phases



$$s_j = \sum_{k \sim j} v_j \left(\frac{v_j - v_k}{z_{jk}} \right)^*$$

Power Flow Eqs.

joint & marginal probability distributions

UNCLASSIFIED

Inverse Stochastic Problem: Power Flow (static/minutes)

Given:

- ~~operational~~ grid=graph, inductances/resistances
- **snapshots/measurements** of power flows, voltages, phases
- parametrized representation for **statistics** of injections/consumptions, e.g. Gaussian & white

Infer/Learn:

- parameters for **statistics** of the injection/consumption
- operational grid=graph


Sample/Predict:

- configurations of injection/consumption
=> direct problem (compute)



$$s_j = \sum_{k \sim j} v_j \left(\frac{v_j - v_k}{z_{jk}} \right)^*$$

Power Flow Eqs.



UNCLASSIFIED

Machine Learning for the Grid (at least some part) = Automatic Solution of the Inverse Grid Problem(s)

Many flavors:

- static vs dynamic
- transmission vs distribution
- blind (black box) vs grid/physics informed
- samples vs moments (sufficiency)
- principal limits (IT) vs efficient algorithms
- ML for model reduction
- individual devices vs ensemble learning



[focus only on some of these ``complexities'' in the talk]

UNCLASSIFIED

- Intro: Overview of Challenges and Approaches
- Technical Intro: Direct and Inverse Stochastic Problem
–Machine Learning for Grid Operations
- **Machine Learning for Distribution Grid**
- Machine Learning for Transmission Grid
- Graphical Models & New Physics=Grid Informed Learning Tools

UNCLASSIFIED

Machine Learning for **Distribution Grid**

D. Deka, S. Backhaus, MC
arxiv:1502.07820, 1501.04131, +

Learn




- Switch statuses
- Load statistics, line impedances

Challenges

- Nodal Measurements (voltages)
- Missing Nodes
- Information limited to households

Key Ideas

- Operated **Radial** structure
- **Linear-Coupled** power flow model
- Graph Learning tricks



UNCLASSIFIED

Machine Learning for **Distribution** Grid

D. Deka, S. Backhaus, MC
arxiv:1502.07820, 1501.04131, +


Linear-Coupled power flow model:


$$P_a + iQ_a = \sum_{(a,b) \text{ is edge}} V_a e^{i\theta_a} (V_a e^{-i\theta_a} - V_b e^{-i\theta_b}) / (R_{ab} - iX_{ab})$$

$V_a \approx 1, \theta_a - \theta_b \approx 0$  equivalent to
LinDistFlow (Baran-Wu)


$$\theta = H_{1/X}^{-1} P - H_{1/R}^{-1} Q, \quad V = H_{1/R}^{-1} P + H_{1/X}^{-1} Q$$

$$H_{1/R} = M^T R^{-1} M$$


reduced
Laplacian
matrix


reduced
Incidence
matrix

Inverse Matrices
are computable
explicitly on trees



UNCLASSIFIED

Machine Learning for **Distribution** Grid

D. Deka, S. Backhaus, MC
arxiv:1502.07820, 1501.04131, +

Key Idea:

- Use *variance of voltage diff.* as edge weights



$$\phi_{ab} = \mathbb{E}[(V_a - \mu_{V_a}) - (V_b - \mu_{V_b})]^2$$

- Minimal value outputs the *nearest neighbor*

$$\phi_{ab} < \phi_{ac}$$

Learning Algorithm:

- Min spanning tree* with variance of voltage diff. as edge weights
- ✓ No other information needed
- ✓ Low Complexity: $O(E \log E)$
- ✓ Can learn covariance of fluctuating loads



UNCLASSIFIED

Machine Learning for **Distribution** Grid



D. Deka, S. Backhaus, MC
arxiv:1502.07820, 1501.04131, +

Learning with **missing nodes**:

- Missing nodes separated by 2 or more hops

Learning Algorithm:

- Min spanning tree* with available nodes
- Starting from leaf, check *missing node*



Machine Learning for **Distribution** Grid


D. Deka, S. Backhaus, MC
arxiv:1502.07820, 1501.04131, +

Learning with **missing nodes** & **reduced information**:

- Missing nodes separated by *2 or more hops*
- Model reduction, ensemble (sampling distributions)

Extensions:

- ✓ Learn using **end-node (household)** data accounting for
 - ✓ mix of active (with control) & passive
 - ✓ dynamics of loads/motors and inverters
 - ✓ emergencies, e.g. FIDVR
- ✓ Learn 3 phase unbalanced networks
- ✓ Learn loopy grid graph
 - ✓ cities (Manhattan)
 - ✓ rich exogenous correlations (loops representing non-grid knowledge)
- ✓ Coupling to other physical infrastructures
 - gas/water distribution
 - thermal heatinge.g. extending the learning methodology to the more general “physical flow” networks



UNCLASSIFIED

Recently Awarded GMLC:

Topic 1.4.9 Integrated Multi Scale **Data Analytics** and **Machine Learning** for the Grid

PIs:

Emma Stewart (LBNL)


Michael Chertkov (LANL)

NL involved:

LBNL, LANL, SNL, ORNL, LLNL, NREL, ANL

- Platform
 - review
 - development,
 - data collection
- ML and Data Analytics for Visibility
- ML and Data Analytics for Resilience

Road Map of 1.4.9 (ML for distribution grids)



UNCLASSIFIED



Integrating Distrib.-Level (stochastic) Loads in Frequency Control

Idea: Use distribution level Demand Response (DR), specifically ensemble of Thermostatically Control Loads (TCL), to balance SO signal through Aggregator (A)

- Thousands of TCLs are aggregated
- SO → Aggregator (A) → TCLs [top → bottom]
- Aggregator is seen (from above) as a “virtual GEN”
 - Goal of the study to answer the principal question:
 - Can A follow the SO's real-time signal as an actual GEN?**
- ... and do it under “social welfare” conditions [our novel approach]:
 - TCLs are controlled by the aggregator in a **least intrusive** way
 - broadcast of a few control signals (switching [stochastic] **rates**, temperature **band**)
 - probability distribution (PD)** over states (temperature, +/-) is the control variable


Results & Work in Progress:

- Builds on theory & simulation experience from Nonequilibrium StatMech & Control
- Stochastic/PDE/spectral methods for analysis of the PD (“driven” Fokker-Planck) were developed and cross-validated
- Ensemble Control Scheme (“second quantization”= Bellman-Hamilton-Jacobi approach for PD) is formulated ... testing.




UNCLASSIFIED

Fault-Induced Delayed Voltage Recovery




Challenges:

- Describe FIDVR quantitatively
- Learn to detect it fast
- Predict if a developing event will or will not lead to recovery? Cascade?
- Develop minimal preventive emergency controls



Example of a Small Fault → feeder is partially stalled (Movie Small Fault)




Work in progress:

- Effects of other devices (controlled or not)
- Preventive/emergency control

Results:


- Reduced PDE model was developed
- Distributed Hysteretic behavior was described
- Effects of disorder and stochasticity were analyzed
- Effect of cascading from one feeder to another and possibly further to transm. was investigated



Hysteretic behavior/stalling

UNCLASSIFIED

Optimal Distributed Control of Reactive Power via ADMM



$$p_j + iq_j =$$

$$p_j^{(c)} - p_j^{(g)} \quad q_j^{(c)} - q_j^{(g)}$$


reactive control of
j-th PV inverter

s_j j-th PV-inverter
reactive capability

$$-\sqrt{s_j^2 - (p_j^{(g)})^2} \leq q_j^{(g)} \leq \sqrt{s_j^2 - (p_j^{(g)})^2}$$

Challenges:

- Develop algorithm to control voltage and losses in distribution
- Do it using/exploring new degree of freedom
= reactive capabilities of inverters



Case	Loss ^g	Loss ^l
1	0.834	0.845
2	0.941	0.949
3	0.847	0.890
4	0.954	0.962
6	0.700	0.771

local vs global

$$\min_{q^{(g)}, P, Q, V} \sum_{j=0}^{n-1} r_j \frac{P_j^2 + Q_j^2}{V_j^2} = \text{Losses}$$

s.t.

Power Flow Equations

$$\forall j = 1, \dots, n :$$

$$(1 - \epsilon)^2 V_0^2 \leq V_j^2 \leq (1 + \epsilon)^2 V_0^2$$

$$|q_j^{(g)}| \leq \sqrt{s_j^2 - (p_j^{(g)})^2}$$

Results:

- The developed control (based on the LinDistFlow representation of the Power Flows in distribution is
 - Distributed (local measurements + communications with neighbors)
 - Efficient = implemented via powerful ADMM) (Alternative Direction Method of Multipliers)

Validated on realistic distribution circuits

Case	Nodes	PV-pen	$p_{\max}^{(c)}$	$p^{(g)}$	s_{\max}
1	100	100%	4 kW	1 kW	1.1 kW
2	100	50%	4 kW	1 kW	1.1 kW
3	250	50%	2.5 kW	1 kW	2.2 kW
4	250	50%	1 kW	2 kW	2.2 kW
5	200	100%	3.75 kW	0 kW	2.2 kW
6	150	85%	4 kW	0.9 kW	1.1 kW
7	150	70%	2 kW	6.5 kW	10 kW


UNCLASSIFIED

Resilient Distribution Systems (Bent, Backhaus, Yamangil, Nagarajan) Slide 21

Goal: Withstand the initial impact of large-scale disruptions

Develop tools, methodologies, and algorithms to enable the design of resilient distribution systems, using


- Asset hardening
- System expansion by adding new:
 - Lines/circuit segments
 - Switching
 - Microgrid facilities
 - Microgrid generation capacity
- Binary decisions, mixed-integer programming problem



Source: Department of Energy, Office of Electricity Delivery and Energy Reliability



Rural



Observations

- Rural networks require larger resilience budgets/MW served.
 - Microgrids favored over hardened lines
- Urban budget is insensitive to critical load requirements
 - Minimal hardening of lines achieves resilience goals

Model

Given a graph $G = (V, E)$ where V and E corresponds to **node based and edge based upgrades**, respectively, and S a **set of disaster scenarios**, we want to find:

$$\begin{aligned}
 &\min \text{Budget}(G') \\
 &\text{s.t. } G' \subseteq G \\
 &\quad T_s \subseteq G' \quad \forall s \in S \\
 &\quad T_s \in \text{OperatingConditions}(G) \quad \forall s \in S \\
 &\quad \text{CriticalDemand}(T_s) \geq \text{MinCriticalDemand} \quad \forall s \in S \\
 &\quad \text{TotalDemand}(T_s) \geq \text{MinTotalDemand} \quad \forall s \in S
 \end{aligned}$$

A simplified model


1st stage:
construction
variables

2nd stage:
assets in use


**Block
diagonal
structure:**
coupling
variables.

LinDistFlow:
3-phase
unbalanced
AC power flow

Relaxations



Algorithm



UNCLASSIFIED

- Intro: Overview of Challenges and Approaches
- Technical Intro: Direct and Inverse Stochastic Problem
–Machine Learning for Grid Operations
- Machine Learning for Distribution Grid
- **Machine Learning for Transmission Grid**
- Graphical Models & New Physics=Grid Informed Learning Tools

UNCLASSIFIED

Machine Learning for the **Transmission** Grid:

Ambient Stage

D. Deka, S. Backhaus, MC +
work in progress

Learn


- Inertia, damping for generators
- Key parameters for (aggregated) loads (state estimation)
- Statistics of spatio-temporal fluctuations (statistical state estimation)
- Critical wave-modes (speed of propagation, damping)

Challenges

- Limited measurements
- Incorporating PMU with SCADA
- On-line requirements,
e.g. need linear scaling algorithms

Key Ideas

- **Temporal scale separation:**
slow (tens of mins) vs fast (tens of secs)
- **Learning stochastic ODEs** – generalized stochastic swing equations
- **Spatial aggregation** – incorporating PDEs
- **Green function approach** (extending Backhaus & Liu 2011 beyond detailed balance)



UNCLASSIFIED

Machine Learning for the **Transmission** Grid:

Detection & Mitigation of Frequency Events

D. Deka, S. Backhaus, MC +
work in progress

Learn

- Detect, localize & size frequency events in almost real time, utilizing ambient state estimation



Challenges

- Spatio-temporally optimal, fast measurements
- Have a fast predictive power – is an extra control needed? when? where?

Key Ideas

- Modeling: **electro-mechanical waves** over 1d+ and/or 2d aggregated media, **forerunner** (shortest path), **interference** pattern

$$M\partial_t^2\theta + \tau\partial_t\theta = D\partial_x^2\theta + A\delta(t - t_0)\delta(x - x_0)$$




Machine Learning for the **Transmission** Grid: Industry-grade Implementation

GMLC 2.0 proposal
in collaboration with
LBNL, PNNL, Columbia U

Goal:

- Develop data aided architecture
 - Database of past events
 - Combine PMU with SCADA + (aggregated) uPMU
- ✓ Grid-informed ML Analysis (just discussed) and New Tools (advanced visualization, events detection)
 - ✓ Validation against and developing industry standards
 - Principal Component Analysis
 - Existing software (PPMV, FRAT)
 - ✓ Optimal sizing/sampling of PMUs



UNCLASSIFIED

- Intro: Overview of Challenges and Approaches
- Technical Intro: Direct and Inverse Stochastic Problem
–Machine Learning for Grid Operations
- Machine Learning for Distribution Grid
- Machine Learning for Transmission Grid
- Graphical Models & New Physics/Grid Informed ML-tools

UNCLASSIFIED

01/18-22/16

cnls.lanl.gov/machinelearning




PHYSICS INFORMED MACHINE LEARNING

UNCLASSIFIED

Graphical Models for Power Systems (and beyond)

3-bus Power System
v-voltage
s-(apparent) power



$$x_j = (v_j, s_j) \quad x_{j \rightarrow k} = (v_{j \rightarrow k}, s_{j \rightarrow k})$$


$$a \in (j, k, l, j \rightarrow k, k \rightarrow j, k \rightarrow l, l \rightarrow k, j \rightarrow l, l \rightarrow j)$$

$$f_j(x_j, x_{j \rightarrow k}, x_{j \rightarrow l}) = I(s_j, s_{j \rightarrow k} + s_{j \rightarrow l}) * I(v_j, v_{j \rightarrow k}, v_{j \rightarrow l}) * \text{Prob}(s_j)$$

$$f_{jk}(x_{j \rightarrow k}, x_{k \rightarrow j}) = I\left(s_{j \rightarrow k}, v_{j \rightarrow k} \left(\frac{v_{j \rightarrow k} - v_{k \rightarrow j}}{z_{jk}}\right)^*\right) * I\left(s_{k \rightarrow j}, v_{k \rightarrow j} \left(\frac{v_{k \rightarrow j} - v_{j \rightarrow k}}{z_{jk}}\right)^*\right)$$

power flows

exogenous nodal
statistics



e.g. opens it up
for **new**
Machine Learning +
solutions


Universal formulations for all statistical objects of Interest:

- **Marginal Probability** of voltage at a node - $P(v_j) = \sum_{x \setminus v_j} P(x)$
- **Most probable** load/wind at a node [instanton]
keeping voltages within a domain - $\text{argmax}_{s_j} \sum_{x \setminus (s_j)} P(x)_{v \in \text{Dom}_v}$
- **Stochastic Optimum Power Flows** (CC-, robust-) + dynamic (multi-stage) + planning ++
- Allows to incorporate multiple "complications"
 - Any deterministic **constraints** (limits, inequalities), e.g. expressing feasibility
 - Any mixed (discrete/continuous) **variables**, e.g. switching

Complexity of Learning: Easy vs Hard

Slide 29

- **Direct Problem** – Statistical Inference (marginal, partition function, ML)
- **Inverse Problem** – Learning (graphs & factors) from samples



- **New Story** (2015) – Don't follow the sufficient statistics path
- Focus on Sample and Computational Complexity of finite GM Learning
- Provably efficient "**local**" optimization schemes (binary, pair-wise GM)
 - based on "**conditioning**" to vicinity of a local variable
- based on "**screening**" interaction through an accurate choice of the optimization cost
- generalizable – applies directly to an **arbitrary GM**

[Bressler 2015]

[M. Vuffray, A. Lokhov, S. Misra, MC 2016]

Summary & Path Forward

- **ML for distribution** – PF-aware spanning tree algorithm to learn structure (forest) and correlations of loads
- **ML for transmission** – two-state on-line learning – ambient + emergency [learning parameters of ODEs, model reduction, waves]
- **Graphical Models** – proper language for variety of stochastic grid problems, e.g. related to learning.
 - Recent progress in **GM learning** -light, distributed, provably exact schemes – applies naturally to the grid-specific (and other physical network-specific) ML problems.
 - New relaxation ideas based on adaptive **Linear Programming – Generalized Belief Propagation schemes** – complementary to “standard” relaxations for OPF & related

UNCLASSIFIED

LANL Grid Science Team



S. Backhaus



R. Bent



M. Chertkov



C. Coffrin



A. Zlotnik



S. Misra



M. Vuffray



H. Nagarajan



C. Borraz-Sanchez



A. Lokhov



E. Yamangil




D. Deka

UNCLASSIFIED


The Ising Model Learning Problem

Generate M i.i.d. samples
of binary sequences



$$\mu(\sigma_1, \dots, \sigma_N) \propto \prod_{(i,j) \in E} \exp(J_{ij} \sigma_i \sigma_j)$$



$$\begin{pmatrix} \sigma_1^{(1)}, \dots, \sigma_N^{(1)} \\ \vdots \\ \sigma_1^{(M)}, \dots, \sigma_N^{(M)} \end{pmatrix}$$



Reconstruct graph and
couplings with high
probability



Learning is Easy in Theory & Practice

Number of variables: N

Maximum node degree: d

Number of samples: M

Coupling intensity: $J_{min} \leq |J_{ij}| \leq J_{max}$

Complexity: $\exp\left(\frac{e^{c_1 d J_{max}}}{J_{min}^{c_1}}\right) N^2 \log N$ Samples Required: $\exp\left(\frac{e^{c_1 d J_{max}}}{J_{min}^{c_1}}\right) \log N$

Bresler (2015)
Structure Learning

Complexity: $\frac{e^{8dJ_{max}}}{J_{min}^2} N^3 \log N$ Samples Required: $\frac{e^{8dJ_{max}}}{J_{min}^2} \log N$

Vuffray et al. (2016)
Structure + Parameter
Learning

We develop **new model estimators**: (Regularized) Interaction Screening Estimators

They are **consistent estimators** for **all graphical models** (Continuous variables, general interactions, etc...)

Provably optimal on **arbitrary** Ising Models, distributed

The Screening Estimator(s)

Number of samples: ∞

$$f_u(\theta) = \left\langle \prod_{j \neq u} \exp(-\theta_{ju} \sigma_j \sigma_u) \right\rangle$$

$$\hat{J}_u = \operatorname{argmin}_{\theta} f_u(\theta)$$

Number of samples: M

$$f_u^M(\theta) = \frac{1}{M} \sum_{k=1, \dots, M} \prod_{j \neq u} \exp(-\theta_{ju} \sigma_j^{(k)} \sigma_j^{(k)})$$

$$\hat{J}_u^M = \operatorname{argmin}_{\theta} f_u^M(\theta) + \lambda_{N,M} \|\theta\|_1$$

Regularizer reduces # of samples required:
 $O(N \ln N) \rightarrow O(\ln N)$